

iVAR COB Downlight

DLD07-025

Features:


- * Use die-casting magnesium alloy to make the main body.
- * Use PMMA as the material of panel.
- * Unique and delicate looking design.
- * Excellent heat dissipation performance.
- * The driver and main body use separation design which ensure the long life of both parts.
- * Energy saving LED driver.
- * Can replace traditional downlight.







Dimenions(unit:mm/inch):



Application:

Widely used in hotel, house, office, parking lot, exhibition, club and other places need indoor lighting.








Specifications:

Model Number	Color	LED Type	Light Output (lumen)	ССТ	CRI	Beam Angle (degrees)	Power (W)	Max.Current (mA)	Voltage (VAC)	weight (Kg)	PF
DLD07-025-AW-W-01	White	Epistar COB LED	2480	6000-6300	>80	65°	25W	280	100-240V AC 50/60Hz	0.88	>0.9
DLD07-025-AW-WW-01	Warm White		2260	2900-3100	>80						
DLD07-025-AW-NW-01	Natural White		2440	3900-4100	>80						

Installation drawing:



Package Information:

Inner box dimension: 220*210*123MM

Product net weight: 0.65KG Product gross weight: 0.81Kg Carton box dimension (12PCS inside): 460*430*390MM

Other cautions:

Power must be cut off before installation, fix it on the position of installation holes, connection of the power supply must be sealed.

- 1.Please read the specification first, to make sure the service environment matches the condition in the specification before using.
- 2.Please confirm the applicable power supply before using.
- 3.Make sure the switch of product is off before connect to the power supply to prevent electric shock.
- 4. Operation against rules may damage your property even harm to your personal safety.
- 5.Preliminarily estimate required quantity of LED lights, then according to the power rating of single flood light to figure out the total power and design power supply plan.
- ${\it 6.} Dangerous \ high \ voltage, \ Non-professionals \ are \ not \ allowed \ to \ maintain \ the \ products.$
 - If the exterior flexible cable or wire is damaged, it must exchange by the supplier, its agent or other similar qualified personnels to avoid dangers.